

05/21/2024

Wisconsin Department of Natural Resources required Sanitary Sewer Overflow (SSO) Notification.

Due to heavy rainfall and strong winds the Village of Mount Calvary was without power from 9:30 pm 5/21/24 to 3:15 am 5/22/24. Heavy rainfall had caused the lift station at the end of Herman Street to overflow. The lift station was bypassed and approximately 7800 gallons were bypassed to the wetland downstream the night of 5/21/24.

Village of Mount Calvary.